


**MERV 8 Odor Ban Space-Gard  
Furnace Filter  
(QFI077)**



**Performance Data -  
Space Baron Research Products "Space-Gard 2200 & 2400"**

Product Code	ASHRAE 52.2 - 1999				Initial Resistance "w.g."		Final Resistance "w.g."	
	MERV Value	E1 %	E2 %	E3 %	@ 1032 cfm	@ 1000 cfm	@ 1032 cfm	@ 1000 cfm
					20x25x6 MERV8	8	n/a	n/a
20x25x6 MERV11	11	n/a	n/a	n/a	0.1	-	.50	-
20x25x6 Odor	8	n/a	n/a	n/a	0.07	-	.50	-
16x27x6 MERV8	8	n/a	n/a	n/a	-	0.09	-	.50
26x27x6 MERV11	11	n/a	n/a	n/a	-	0.11	-	.50
16x27x6 Odor	8	n/a	n/a	n/a	-	0.06	-	.50

Description	Nominal Dimensions	Actual Frame Dimensions
Space-Gard MERV 8	20" x 25" x 6"	19.75" x 24.25" x 6"
Space-Gard MERV 8	16" X 27" x 6"	15.5" x 27" x 6"
Space-Gard MERV 11	20" x 25" x 6"	19.75" x 24.25" x 6"
Space-Gard MERV 11	16" X 27" x 6"	15.5" x 27" x 6"
Space-Gard MERV 8 Odor	20" x 25" x 6"	19.75" x 24.25" x 6"
Space-Gard MERV 8 Odor	16" X 27" x 6"	15.5" x 27" x 6"